

**TECHNICAL DATA****PILOT PRESSURE
REGULATED DELUGE SYSTEM
CONTROLLED BY ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

1. DESCRIPTION

(Refer to Figures 1, 2 or 3.)

A Viking Pilot Pressure Regulated Deluge System utilizes a Viking flow control valve to control water flow into the deluge system. The flow control valve must be installed with Pilot Regulating Deluge Trim. Release trim for electrically operated systems utilizes an electric solenoid valve controlled by an approved system control panel and compatible detection system.

The Pilot Pressure Regulated Deluge System is recommended where it is necessary to maintain a predetermined discharge pressure after the system operates. This feature allows regulation of total system demand and can be used to limit excess flow from deluge systems with high pressure water supplies. The system is also recommended where a reduction of pressure surges and/or water hammer is desired.

2. LISTINGS AND APPROVALS

The Viking electrically controlled Pilot Pressure Regulated Deluge System is UL Listed on a component basis. Refer to the current UL Listing Guide. Consult the manufacturer for any component approvals too recent to appear in the UL Listing Guide.

3. SYSTEM OPERATION

(Refer to Figures 1, 2 or 3.)

A. IN THE SET CONDITION

System water supply pressure enters the priming chamber of the flow control valve (A.1) through the priming line, which includes a normally open priming valve (B.1), strainer (B.2), restricted orifice (B.3), and check valve (B.4). In the SET condition, water supply pressure is trapped in the priming chamber by the check valve (B.4) and normally closed solenoid valve (G.1) in the release trim. The pressure in the priming chamber holds the flow control valve clapper closed, keeping the atmospheric chamber and deluge system piping dry.

B. IN FIRE CONDITIONS

In fire conditions, when the detection system (G.4) operates, system control panel (G.3) energizes solenoid valve (G.1) open. Pressure is released from the priming chamber faster than it is supplied through restricted orifice (B.3). The flow control valve clapper opens to allow water to flow into the system piping and alarm devices (C.1, C.2).

C. PRESSURE REGULATION

When the flow control valve (A.1) operates, water released from its priming chamber enters the inlet of pilot pressure regulating valve (F.1). The sensing line (F.2) connects the deluge system piping, downstream of flow control valve (A.1), to the outlet chamber of the pilot pressure regulating valve (F.1). When downstream pressure rises above the set point of the pilot pressure regulating valve (F.1), flow through the pilot pressure regulating valve is stopped. When downstream pressure falls below the set point, flow through the pilot pressure regulating valve resumes. The regulated flow through the pilot pressure regulating valve controls the pressure in the priming chamber of the flow control valve to open or close the clapper as required to regulate downstream system pressure.

4. INSTALLATION

Systems must be installed and maintained in accordance with applicable NFPA 13, 14 and NFPA 25, local Authorities Having Jurisdiction, and Viking Technical Data referenced below.

Refer to current Viking Technical Data describing individual components of the Viking Pilot Pressure Regulated Deluge System. Technical Data describing the Viking flow control valve, the Viking pilot pressure regulating valve, the Viking speed control assembly, pilot regulating deluge trim, and other system components are packed with product and in the *Viking Engineering and Design Data* book.



TECHNICAL DATA

**PILOT PRESSURE
REGULATED DELUGE SYSTEM
CONTROLLED BY ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

5. PLACING THE SYSTEM IN SERVICE

(Refer to Figures 1, 2 or 3.)

NOTE: FOR NEW INSTALLATIONS, OR IF ADJUSTMENT OF OPENING OR CLOSING SPEED OF THE FLOW CONTROL VALVE IS NECESSARY, OR IF DOWNSTREAM PRESSURE ADJUSTMENT IS NECESSARY, REFER TO INSTRUCTIONS PROVIDED IN TECHNICAL DATA DESCRIBING THE VIKING FLOW CONTROL VALVE, THE VIKING SPEED CONTROL ASSEMBLY, AND THE VIKING PILOT PRESSURE REGULATING VALVE.

To Return a System to Service:

1. Verify that the system has been properly drained. System main drain (D.2) and auxiliary drain (B.6) should be open. Verify that emergency release (B.11) is closed.
2. Close the system main drain (D.2).
3. Open the priming valve (B.1).
4. Reset the system control panel (G.3). For the Viking VFR400 Release Control Panel, open the panel and press "RESET". The solenoid valve (G.1) should close.
5. Open the flow test valve (B.15).
6. Partially open the main water supply control valve (D.1).
7. When full flow develops from the flow test valve (B.15), close the flow test valve.
 - a. Verify that there is no flow from the open auxiliary drain (B.6).
8. Close the auxiliary drain (B.6).
9. Fully open and secure the main water supply control valve (D.1).
10. Verify that the alarm shut-off valve (B.9) is open and that all other valves are in their normal operating position.

CAUTION: Any air in the water supply or air trapped in the priming chamber of the flow control valve may result in severe water hammer and cycling, which can cause damage to the valve, connected piping and associated equipment.
11. To ensure smooth regulation, all air must be removed from the priming chamber of the flow control valve.
 - a. Temporarily close the three-way globe valve at the highest water gauge connection (B.12) in the Flow control valve trim and remove the 1/4" Plug.
 - b. Open the three-way globe valve (water will flow from the opening).
 - c. When all air has been removed, close the three-way globe valve and replace the 1/4" plug.
 - d. Open the three-way globe valve.
12. To verify downstream pressure adjustment, refer to section 7. VERIFY DOWNSTREAM PRESSURE ADJUSTMENT.

6. EMERGENCY INSTRUCTIONS

(Refer to Figures 1, 2 or 3.)

To Take the System Out of Service:

WARNING: PLACING A CONTROL VALVE OR DETECTION SYSTEM OUT OF SERVICE MAY ELIMINATE THE FIRE PROTECTION CAPABILITIES OF THE SYSTEM. PRIOR TO PROCEEDING, NOTIFY ALL AUTHORITIES HAVING JURISDICTION. CONSIDERATION SHOULD BE GIVEN TO EMPLOYMENT OF A FIRE PATROL IN THE AFFECTED AREAS.

After a fire, verify that the fire is OUT and that placing the system out of service has been authorized by the appropriate Authority Having Jurisdiction.

1. Close the main water supply valve (D.1).
2. Open the system main drain (D.2).
3. Silence alarms (optional).
 - a. To silence electric alarms controlled by Viking VFR400 Release Control Panel (G.3), open the panel and press "BUZZER SILENCE".
 - b. To silence the water motor alarm (C.2), close the alarm shut-off valve (B.9).

NOTE: ELECTRIC ALARMS CONTROLLED BY A PRESSURE SWITCH INSTALLED ON THE 1/2" (15 mm) NPT CONNECTION FOR NON-INTERRUPTIBLE ALARM PRESSURE SWITCH CANNOT BE SHUT OFF UNTIL THE FLOW CONTROL VALVE IS RESET OR TAKEN OUT OF SERVICE.

4. Open the auxiliary drain (B.6).
5. Close the priming valve (B.1).

NOTE: SPRINKLER SYSTEMS THAT HAVE BEEN SUBJECTED TO A FIRE MUST BE RETURNED TO SERVICE AS SOON AS POSSIBLE. THE ENTIRE SYSTEM MUST BE INSPECTED FOR DAMAGE, AND REPAIRED OR REPLACED AS NECESSARY.



TECHNICAL DATA

PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

6. Replace any detectors that have been damaged.
7. Replace any sprinklers and/or nozzles that have been damaged or exposed to fire conditions.
8. Perform all maintenance procedures recommended in Technical Data describing individual components of the system that has operated.
9. Return the system to service as soon as possible. Refer to section 5. PLACING THE SYSTEM IN SERVICE.

7. VERIFY DOWNSTREAM PRESSURE ADJUSTMENT

(Refer to Figures 1, 2 or 3.)

It is recommended that the desired discharge pressure of the system be adjusted with a minimum flow of 25 GPM (95 LPM) or greater flowing through the flow control valve.

For deluge systems, where flow through open sprinklers and/or nozzles is not practical, a test valve (D.5 - Model H Valve and D.4 - Model J Valve) with discharge pipe must be provided in the riser between the flow control valve (A.1) and an isolation valve (D.4 Model H Valve and D.3 - Model J Valve).

1. For deluge systems, if the use of open sprinklers and/or nozzles is not practical, CLOSE the system isolation valve (D.4 - Model H Valve and D.3 - Model J Valve) and OPEN the system test valve (D.5 - Model H Valve and D.4 - Model J Valve).
2. Open and pull the handle of the emergency release (B.11) to open the flow control valve. Establish a minimum flow of 25 GPM (95 LPM) or greater and observe the downstream pressure gauge.
3. If adjustment of the pilot pressure regulating valve is necessary, refer to instructions provided in Technical Data describing the pilot pressure regulating valve.
4. When downstream pressure adjustment has been verified:
 - a. Close the main water supply control valve (D.1).
 - b. Close the emergency release (B.11).
 - c. If closed in step 1, open the system isolation valve (D.4 - Model H Valve and D.3 - Model J Valve) and close the system test valve (D.5 - Model H Valve and D.4 - Model J Valve).

NOTE: The pressure gauge (F.3) installed on outlet piping from the pilot pressure regulating valve may indicate static pressure approximately 8 to 10 PSIG higher than the outlet "set" pressure determined above. This is due to changes in flow velocity that may occur when flow through the system is stopped. Actual "set" pressure should not be affected.

5. To return the system to service, perform steps 1 through 10 of section 5. PLACING THE SYSTEM IN SERVICE.

8. INSPECTIONS AND TESTS

NOTICE: THE OWNER IS RESPONSIBLE FOR MAINTAINING THE FIRE PROTECTION SYSTEM AND DEVICES IN PROPER OPERATING CONDITION.

It is imperative that the system be inspected and tested on a regular basis in accordance with NFPA 25. Refer to INSPECTIONS and TESTS recommended in current Viking Technical Data describing individual components of the Viking Pilot Pressure Regulated Deluge System used. (See section 9 for hyperlinks to Viking Technical Data.)

The frequency of the inspections may vary due to contaminated water supplies, corrosive water supplies, corrosive atmospheres, as well as the condition of the air supply to the system. For minimum maintenance and inspection requirements, refer to NFPA 25. In addition, the Authority Having Jurisdiction may have additional maintenance, testing, and inspection requirements that must be followed.

WARNING: Any system maintenance that involves placing a control valve or detection system out of service may eliminate the fire protection capabilities of that system. Prior to proceeding, notify all Authorities Having Jurisdiction. Consideration should be given to employment of a fire patrol in the affected areas.

9. ORDERING INFORMATION

To order a complete Electric Release Pilot Pressure Regulated Deluge System, order the following: Pressure Regulation Trim Package [includes Deluge Valve Conventional Trim, and Pilot Regulator Trim, as well as the Speed Control Assembly, and Pilot Pressure Regulating Valve]. Order the following separately: Flow Control Valve, Solenoid Valve, Release Control Panel, and Electric Release Trim package.

	<h1 style="margin: 0;">TECHNICAL DATA</h1>	<p>PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE</p>
---	--	---

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Flow Control Valve Part Numbers

Angle Style Valves				
	DESCRIPTION	NOMINAL SIZE	PART NUMBERS	
			Painted Red	HALAR®
Threaded NPT	Pipe O.D.		Model H-3	Model H-4
	48 mm	1½" / DN40	09894	09895Q/B
			Model H-1	Model H-2
	60 mm	2" / DN50	05856C	08365Q/B
Flange/Flange	Flange Drilling		Model H-1	Model H-2
	ANSI	3"	05914C	08366Q/B
	ANSI	4"	05911C	08367Q/B
	ANSI	6"	05908C	08368Q/B
	ANSI/Japan	4"	09037	----
	ANSI/Japan	6"	09386	----
	PN10/16	DN80	08627	08873Q/B
	PN10/16	DN100	08630	08874Q/B
	PN10/16	DN150	08632	08875Q/B
Flange/Groove	Flange Drilling / Pipe O.D.		Model H-1	Model H-2
	ANSI / 89 mm	3"	05837C	11207Q/B
	ANSI / 114 mm	4"	05841C	11208Q/B
	ANSI / 168 mm	6"	05458C	11209Q/B
	PN10/16 / 89 mm	DN80	11658	----
	PN10/16 / 114 mm	DN100	11811	----
	PN10/16 / 168 mm	DN150	05458C	11209Q/B

Note: When viewing this datapage online, Part Numbers displayed in BLUE are hyperlinks. Clicking the part number will open the corresponding Technical Data Page.

Straight Through Valves				
	DESCRIPTION	NOMINAL SIZE	PART NUMBERS	
			Painted Red	HALAR®
Threaded NPT	Pipe O.D.		Model J-1	Model J-2
	NPT 48 mm	1½"	12130	----
	NPT 60 mm	2"	12063	----
	NPT 65 mm	2½"	12405	12406Q/B
	BSP 48 mm	DN40	12684	----
	BSP 60 mm	DN50	12688	----
Flange/Flange	Flange Drilling		Model J-1	Model J-2
	ANSI	3"	12016	12017Q/B
	ANSI	4"	11968	11977Q/B
	ANSI	6"	11970	11979Q/B
	ANSI	8"	11993	11994Q/B
	ANSI/Japan	4"	11975	----
	ANSI/Japan	6"	11981	----
	PN10/16	DN80	12028	12029Q/B
	PN10/16	DN100	11973	11982Q/B
	PN10/16	DN150	11971	11980Q/B
	PN10	DN200	11997	11998Q/B
PN16	DN200	12001	12002Q/B	
Flange/Groove	Flange Drilling / Pipe O.D.		Model J-1	Model J-2
	ANSI / 89 mm	3"	12020	12021Q/B
	ANSI / 114 mm	4"	11967	11976Q/B
	ANSI / 168 mm	6"	11969	11978Q/B
	PN10/16 / 89 mm	DN80	12031	12646Q/B
	PN10/16 / 114 mm	DN100	11974	12647Q/B
	PN10/16 / 165 mm	DN150	12642	12643Q/B
	PN10/16 / 168 mm	DN150	11969	11978Q/B
Groove/Groove	Pipe O.D.		Model J-1	Model J-2
	48 mm	1½" / DN40	12129	12131Q/B
	60 mm	2" / DN50	12061	12062Q/B
	73 mm	2½" / DN65	12407	12408Q/B
	76 mm	DN80	12731	12732Q/B
	89 mm	3" / DN80	12024	12025Q/B
	114 mm	4" / DN100	11516	11517Q/B
	165 mm	DN150	11912	11913Q/B
	168 mm	6" / DN150	11527	11528Q/B
219 mm	8" / DN200	11019	11119Q/B	

	<h1 style="margin: 0;">TECHNICAL DATA</h1>	<h2 style="margin: 0;">PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE</h2>
---	--	---

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Pressure Regulating Trim (Includes Conventional Trim)

DESCRIPTION	NOMINAL SIZE	PART NUMBER		
PRESSURE REGULATING TRIM Includes Deluge Valve Conventional Trim	Rated to 250 psi (1 724 kPa)			
	Use with Angle Style Valves			
		Galvanized	Loose	Modular
		1½" / DN40	----	----
		2" / DN50	14715-1	14715-1P
		2½" / DN65	----	----
		3" / DN80	14716-1	14716-1P
		4" / DN100	14717-1	14717-1P
		6" / DN150	14718-1	14718-1P
		Brass		
		1½" / DN40	----	----
		2" / DN50	14715-2	14715-2P
		2½" / DN65	----	----
		3" / DN80	14716-2	14716-2P
		4" / DN100	14717-2	14717-2P
	6" / DN150	14718-2	14718-2P	
Use with Straight Through Valves				
	Galvanized	Loose	Modular	
Hoz.	1½" / DN40	14750-1	14750-1P	
	2" / DN50	14750-1	14750-1P	
	2½" / DN65	14751-1	14751-1P	
	3" / DN80	14751-1	14751-1P	
	4" / DN100	14752-1	14752-1P	
	6" / DN150	14753-1	14753-1P	
	8" / DN200	14714-1	14714-1P	
Vert.	1½" / DN40	14746-1	14746-1P	
	2" / DN50	14746-1	14746-1P	
	2½" / DN65	14747-1	14747-1P	
	3" / DN80	14747-1	14747-1P	
	4" / DN100	14748-1	14748-1P	
	6" / DN150	14749-1	14749-1P	
	8" / DN200	14713-1	14713-1P	
	Brass			
Hoz.	1½" / DN40	14750-2	14750-2P	
	2" / DN50	14750-2	14750-2P	
	2½" / DN65	14751-2	14751-2P	
	3" / DN80	14751-2	14751-2P	
	4" / DN100	14752-2	14752-2P	
	6" / DN150	14753-2	14753-2P	
	8" / DN200	14714-2	14714-2P	
Vert.	1½" / DN40	14746-2	14746-2P	
	2" / DN50	14746-2	14746-2P	
	2½" / DN65	14747-2	14747-2P	
	3" / DN80	14747-2	14747-2P	
	4" / DN100	14748-2	14748-2P	
	6" / DN150	14749-2	14749-2P	
	8" / DN200	14713-2	14713-2P	

Release Trim Package Part Numbers

ELECTRIC RELEASE TRIM PACKAGES		
Finish	Part Number	
Use with Straight Through and Angle Style Valves		
	Loose	Modular
Galvanized	10830	10830-P
Brass	10832	10832-P
NOTE: Solenoid valve must be ordered separately.		
Solenoid Valve	11601	

Note: When viewing this datapage online, Part Numbers displayed in **BLUE** are hyperlinks. Clicking the part number will open the corresponding Technical Data Page.




TECHNICAL DATA

PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com




VIKING®

TECHNICAL DATA

PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com



**FIGURE 2: PILOT PRESSURE REGULATED DELUGE SYSTEM
CONTROLLED BY ELECTRIC RELEASE SHOWN WITH STRAIGHT THROUGH VERTICAL TRIM**




TECHNICAL DATA

PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com



- SYSTEM COMPONENTS***
- A. Valve
 - A.1 Flow Control Valve
 - B. Deluge Valve Conventional Trim (See Deluge Valve Conventional Trim Charts)
 - B.1 Priming Valve (Normally Open)
 - B.2 Strainer
 - B.3 1/16" Restriction
 - B.4 Spring Loaded Check Valve
 - B.5 Alarm Test Valve (Normally Closed)
 - B.6 Auxiliary Drain Valve (Normally Closed)
 - B.7 Drip Check Valve
 - B.8 Drain Check Valve
 - B.9 Alarm Shut-Off Valve (Normally Open)
 - B.10 Pressure Operated Relief Valve (PORV)
 - B.11 Emergency Release
 - B.12 Priming Pressure Water Gauge and Valve
 - B.13 Water Supply Pressure Gauge and Valve
 - B.14 Drain cup
 - B.15 Flow Test Valve (Normally Closed)
 - C. Water Flow Alarm Equipment
 - C.1 Alarm Pressure Switch and/or
 - C.2 Water Motor Alarm (Strainer Required)
 - C.3 Strainer
 - C.4 Electric Alarm Bell
 - D. Riser
 - D.1 Water Supply Control Valve
 - D.2 Deluge System Main Drain
 - D.3 Optional System Isolation Valve, Normally Open
 - D.4 Optional System Test Valve, Normally Closed
 - E. Speed Control
 - E.1 Speed Control Valve
 - E.2 Strainer
 - F. Pressure Regulating Valve
 - F.1 Viking Pressure Regulating Pilot Valve
 - F.2 Pressure Regulating Valve Trim
 - F.3 Sensing Line Pressure Gauge and Valve
 - F.4 Pressure Relief Valve
 - G. Release System
 - G.1 Solenoid Valve
 - G.2 Electric Release Module (See Electric Release Module Trim Chart)
 - G.3 System Control Panel configured for Single Zone Deluge operation.
 - G.4 Electric Detection System. Heat detector shown for clarity.

--- Dashed lines indicate pipe required but not included with Pilot Regulating Deluge Trim.

..... Dotted lines indicate electrical detection system wiring required but not included with "System Components". For additional wiring requirements refer to technical data for components used.

* Viking Pressure Regulating Trim Packages contain items B.1 through B.15, E.1, E.2, and F.1 through F.4, and associated nipples required to install the Viking Pilot Pressure Regulating Valve on a Viking Flow Control Valve equipped with Deluge Valve Conventional Trim.

** 1/2" (15 mm) NPT for Non-Interruptible Alarm Pressure Switch (Optional)

FIGURE 3: PILOT PRESSURE REGULATED DELUGE SYSTEM CONTROLLED BY ELECTRIC RELEASE SHOWN WITH STRAIGHT THROUGH HORIZONTAL TRIM