

EC CERTIFICATE OF CONFORMITY

1725 - CPD – H0009

In compliance with Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

**Model VK1510 (Plain Barrel Type Pendent),
VK1550 (Standard Adjustable Type Pendent) &
VK1590 (Standard Recessed Adjustable Type Pendent)
Control Mode, Standard Response, Dry Automatic Sprinklers**

K Factor: 5.6 gal/min/psi^{1/2} [80 l/min/bar^{1/2}]

VK1510 & VK1550 Nominal Operating Temperatures: 155, 175, 200 & 286°F (68, 79, 93 & 141°C)

VK1590 Nominal Operating Temperatures: 155, 175 & 200°F (68, 79 & 93°C)

Finishes: Brass, Chrome and Polyester

placed on the market by

The Viking Corporation

210N Industrial Park Dr.

Hastings, MI49058

United States of America

and produced in the factory

The Viking Corporation

210N Industrial Park Dr.

Hastings, MI49058

United States of America

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. 1725 - FM Approvals Limited has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard(s) or in the ETA (*resp. in*)

**EN12259-1:1999 including Amendments A1:2001, A2:2004
and A3:2006 and Corrigendum No.1**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 8th June 2012 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Issue 1, Windsor, dated 8th June 2012

Andrew Was
Certification Manager
On behalf of FM Approvals Limited

Page 1 of 1