

EC CERTIFICATE OF CONFORMITY

1725 - CPD – H0006

In compliance with Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

Model VK520,
K factor: 14.0 gal/min/(psi)^{1/2} [202 l/min/(bar)^{1/2}],
74°C and 96°C, Upright
ESFR Sprinkler
Rated Working Pressure: 12bar (175psi)
For use in Automatic Sprinkler Systems

placed on the market by

Viking SA
Zone Industrielle Haneboesch
L-4562 Differdange/ Niedercom
Luxembourg

and produced in the factory

The Viking Corporation
210 North Industrial Park Road
Hastings
49058 Michigan, USA

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. 1725 - FM Approvals Limited has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard(s) or in the ETA (*resp. in*)

ETA-10/0306

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 20th December 2010 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.