



# Certificate of Compliance

This certificate is issued for the following equipment:

## Control Mode Concealed Pendent Standard Response Automatic Sprinkler

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK492	5.6	Concealed Pendent	SR	Job G5 5mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2015  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055470

Approval Granted: February 19, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D. B. Fuller'.

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



Member of the FM Global Group