

CERTIFICATE OF COMPLIANCE

Certificate Number 20181121-EX3836
Report Reference EX3836-20060803
Issue Date 2018-NOVEMBER-21

Issued to: VIKING CORP
210 INDUSTRIAL PARK DR
HASTINGS MI 49058-9706

**This certificate confirms that
representative samples of**

RESIDENTIAL AUTOMATIC SPRINKLERS; RESIDENTIAL
AUTOMATIC SPRINKLERS CERTIFIED FOR EUROPE
REFER ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Residential Sprinklers for Fire Protection Service UL1626
Residential Sprinklers for Fire Protection Service ULC/ORD
C1626

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181121-EX3836
Report Reference EX3836-20060803
Issue Date 2018-NOVEMBER-21


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

VK488, concealed pendent style sprinkler, discharge coefficient "K" = 3.0, fusible link heat responsive element, 165 and 205°F temperature rated residential type sprinklers with a 135 and 165°F concealed coverplate assembly.

VK4880, (Lead Free) concealed pendent style sprinkler, discharge coefficient "K" = 3.0, fusible link heat responsive element, 165 and 205°F temperature rated residential type sprinklers with a 135 and 165°F concealed coverplate assembly.

*# - Utilizes a 135°F cover plate.

*+ - Utilizes a 165°F cover plate.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

