

# CERTIFICATE OF COMPLIANCE

Certificate Number 20180411-EX3836  
Report Reference EX3836-20160621  
Issue Date 2018-APRIL-11

Issued to: VIKING CORP  
210 INDUSTRIAL PARK DR  
HASTINGS MI 49058-9706

This is to certify that  
representative samples of

RESIDENTIAL AUTOMATIC SPRINKLERS  
VK494 and VK4940 concealed pendent style sprinkler,  
discharge coefficient "K" = 4.9, (3 mm glass bulb type) heat  
responsive element, 155, 175, and 200°F temperature rated  
residential type sprinklers with a 135°F cover plate  
assembly.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1626, Standard for Residential Sprinklers for Fire-  
Protection Service  
ULC/ORD C-1626-03, Other Recognized Document for  
Residential Sprinklers for Fire-Protection Service

Additional Information: See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

