

## **Certificate of Compliance**

This certificate is issued for the following equipment:

## Sprinkler Guards/Shields for Fire Protection

Product	Primary Class of Work	Listing Country	Type	Sprinkler FM Approved with	Sprinkler Types	Certification Type
EG-100	2091-Sprinkler	United States	Guard/Shield	VK506,	Pendent	FM
	Guards	of America		VK510,	Automatic	Approved
				VK514	Sprinklers	

Prepared for: The Viking Corporation

5150 Beltway Drive SE, Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation

10 North Industrial Park Drive, Hastings, MI 49058, USA

or

The Viking Corporation 5150 Beltway Drive SE, Caledonia, MI 49316, USA

FM Approvals Class: 2091

FM Approval Standard: Class Number 200 (February 2018) and Class Number 2008 (February 2018)

Approval Identification: PR462745 Approval Granted: September 20, 2022

To verify the availability of the Approved product, please refer to <a href="www.approvalguide.com">www.approvalguide.com</a>

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fulle

VP, Manager - Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



