

## **Certificate of Compliance**

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	Connection	Finishes	Temperature
							Ratings
							° <b>F</b> (° <b>C</b> )
VK504	16.8	Dry Pendent	QR	Fusible	1.5 in. NPT	Brass	165, 205
			(ESFR)				(74, 96)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive

Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive

Hastings, MI 49058, USA

FM Approvals Class: 2027

FM Approval Standard: Class Series 2008 (October 2006) and Draft Performance Requirements for Quick-Response Standard-Coverage Dry Pendent Storage Automatic Sprinklers (also referred to as Dry Pendent Suppression Mode Sprinklers) with a Nominal Discharge Coefficient of 16.8 gal/min/(psi)<sup>1/2</sup> [240 L/min/(bar)<sup>1/2</sup>] dated August 22, 2013

Approval Identification: 3046999 Approval Granted: January 21, 2015

To verify the availability of the Approved product, please refer to <a href="www.approvalguide.com">www.approvalguide.com</a>

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne

Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group



## **Certificate of Compliance**

This certificate is issued for the following equipment:

Model	K	Туре	Resp.	Element	Connection	Finishes	Temperature Ratings °F (°C)
VK504	16.8	Dry Pendent	QR (ESFR)	Fusible	1.5 in. Grooved	Brass	165, 205 (74, 96)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive

Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive

Hastings, MI 49058, USA

FM Approvals Class: 2027

FM Approval Standard: Class Series 2008 (October 2006) and Draft Performance Requirements for Quick-Response Standard-Coverage Dry Pendent Storage Automatic Sprinklers (also referred to as Dry Pendent Suppression Mode Sprinklers) with a Nominal Discharge Coefficient of 16.8 gal/min/(psi)<sup>1/2</sup> [240 L/min/(bar)<sup>1/2</sup>] dated August 22, 2013

Approval Identification: 3046999 Approval Granted: January 21, 2015

To verify the availability of the Approved product, please refer to <a href="www.approvalguide.com">www.approvalguide.com</a>

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne

Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group