



the standard in safety

Underwriters
Laboratories

File EX5085
Project 06NK11099
Project 07NK08031

Issued: June 18, 2007
Revised: January 31, 2008

REPORT

on

EARLY-SUPPRESSION FAST-RESPONSE (ESFR) SPRINKLERS

Viking Corp.
Hastings, MI

Copyright © 2007 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above named company to reproduce this Report provided it is reproduced in its entirety.

GENERAL

INTRODUCTION:

This Report describes the investigation of Early-Suppression Fast-Response (ESFR) Sprinklers intended to be installed in accordance with the National Fire Protection Association Standard for the Installation of Sprinkler Systems, NFPA 13.

OBJECT:

The object of this investigation was to determine compliance of the ESFR sprinkler with the Standard for Early-Suppression Fast-Response Sprinklers for Fire Protection Service, UL 1767.

PLAN:

The investigation of the ESFR sprinklers consisted of conducting a product conformance evaluation and performance testing as described in UL 1767.

DESCRIPTION

PRODUCT COVERED:

USL, CNL SIN VK503, pendent 16.8 "K-Factor," 3/4 in. NPT inlet, fusible link type, heat responsive element, 165°F and 205°F temperature rated sprinklers have a maximum pressure of 175 psig and a minimum pressure of 50 psig for wet systems only.

CONSTRUCTION DETAILS:

The devices have been examined and found to comply with the Standard for Early-Suppression Fast-Response Sprinklers for Fire Protection Service, UL 1767, in effect as of the date of this Report.

USE:

The product(s) covered by this Report are for use in accordance with the National Fire Protection Association Standard for the Installation of Sprinkler Systems, NFPA 13.


CNL indicates Listing to Canadian National Standard.

CONCLUSION


Samples of the products covered by this Report have been found to comply with the requirements covering the category and the products are judged to be eligible for Listing and Follow-Up Service. The manufacturer is authorized to use the UL Mark on such products which comply with the Follow-Up Service Procedure and any other applicable requirements of Underwriters Laboratories Inc. Only those products which properly bear the UL Mark are considered as Listed by Underwriters Laboratories Inc.

Report by:

Reviewed by:



John R. Serpe
Engineering Associate



Michael G. McCormick
Lead Engineering Associate