



Certificate of Compliance

This certificate is issued for the following equipment:

Control Mode Concealed Pendent Standard Response Automatic Sprinkler

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK492	5.6	Concealed Pendent	SR	Job G5 5mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2015
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055470

Approval Granted: February 19, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group