



Certificate of Compliance

This certificate is issued for the following:

Swing Check Valves
Models D-1, E-1, F-1, and G-1
Sizes: 2-1/2, 3, 4, 6, and 8 inch NPS
(as shown in table below)

Prepared for:

The Viking Corporation
210 N Industrial Park Dr
Hastings, MI 49058
United States

Manufactured at:

The Viking Corporation
210 N Industrial Park Dr
Hastings, MI 49058
United States

FM Approvals Class: 1210 – Swing Check Valves

Approval Identification: 0003042800

Approval Granted: July 08, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne".

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Product Designation	Description	Nominal Pipe Size, in.	Maximum Working Pressure, psi (kPa)	Remarks
Model D-1	Swing Check Valve, Flanged or Grooved Ends	2-1/2	300 (2070)	a
Model E-1	Swing Check Valve, Groove x Groove, Flange x Groove, Flange x Flange Ends	2-1/2	300 (2070)	a
Model F-1	Swing Check Valve, Groove x Groove, Flange x Groove, Flange x Flange Ends	3, 4, 6, 8	300 (2070)	a
Model G-1	Swing Check Valve, Grooved Ends	3	300 (2070)	a
Model G-1	Swing Check Valve, Flanged or Grooved Ends	4, 6, 8	300 (2070)	a

Notes:

- a. For use in horizontal and vertical installations.



Member of the FM Global Group

FACTORY MUTUAL



Factory Mutual Research Corporation
Hydraulics Laboratory
743A Reynolds Road
West Glocester, Rhode Island 02814
Telephone (401) 567-0590
Fax (401) 567-0599

APPROVAL AGREEMENT

The Agreement is made by and between Factory Mutual Research Corporation, (herein called FMRC), and **Viking Corporation, Hastings, MI 49058** (herein called the Client). The Client is making a product or providing a service known and described as:

MODELS D-1AND E-1 CHECK VALVES

IN 2-½ INCH NOMINAL SIZE

MODELS F-1 AND G-1 CHECK VALVES

IN 3, 4, 6, AND 8 INCH NOMINAL SIZES

MODEL J-1 ALARM VALVES


IN 3, 4, 6, AND 8 INCH NOMINAL SIZES


(MODIFICATIONS)

This product or service has been examined by FMRC as described in the report bearing Job Identification **OB4A4.AH** dated, **September 20, 1996** in consideration of FMRC Approval of the product or service the Client authorized to indicate such approval, as stated by the above report, and agrees to the following and terms stated on the reverse side of this Agreement:

1. The Client shall place a unique identification mark (i.e. model or type number) on the product as stated in the above report and shall not place this mark on any other product unless covered by separate agreement with FMRC.
2. The Client shall use the FMRC Approval mark on the product, but shall not use this mark on any other product unless such other product is covered by separate agreement with FMRC.
3. The Client shall not use, reproduce or distribute the above referenced report by FMRC except in its entirety without any change, deletion or addition thereto. The Client agrees that FMRC may distribute the referenced report and related information within the Factory Mutual System.

(SEE OVER)

The Viking Corporation
 _____ Client

 _____ Signature
James G. Retzloff
 _____ Name
Vice President, Design & Development
 _____ Title
210 N. Industrial Park Road
 _____ Title
Hastings MI 49058
 _____ Address
October 21, 1996
 _____ Date

FACTORY MUTUAL RESEARCH CORPORATION
 _____ Signature

 _____ Signature
R.L. Martell
 _____ Name
Asst. V. P. - Approvals Division
 _____ Title
October 4, 1996
 _____ Date