

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 2010

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Model J1 Wet Alarm Valve Assemblies for use in Automatic Sprinkler Installations

(For full product details and conditions of use refer to appendix)

placed on the market by

*The Viking Corporation
210 N Industrial Park Road, Hastings,
Michigan 49058, USA*

and produced in the factory

*The Viking Corporation
210 N Industrial Park Road, Hastings,
Michigan 49058, USA*


is submitted by the manufacturer to a factory production control and that the notified body BRE Certification Limited has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard

EN12259-2:1999 including amendments A1:2001 and A2:2005

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 13 December 2006 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



P J Field
Technical Director
On behalf of BRE Certification Limited

Date of issue: 13 December 2006

Issue number: 1

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

Appendix to EC-Certificate of Conformity 0832 - CPD - 2010

Conditions of Use

The Wet Alarm Valve Assemblies covered by this Certificate of Conformity placed on the market by The Viking Corporation are identified below and must be installed in accordance with the manufacturers installation instructions:

Model	Nominal Size mm	Maximum Working Pressure Bar	Orientation
J1 with C1 Retard Chamber	80, 100, 150, 165(OD) and 200	12	Vertical or Horizontal



P J Field
Technical Director
On behalf of BRE Certification Limited

Date of issue: 13 December 2006

Issue number: 1