

CERTIFICATE OF COMPLIANCE

Certificate Number 20150408-EX5085
Report Reference EX5085-20140407
Issue Date 2015-APRIL-08

Issued to: VIKING CORP
210 N INDUSTRIAL PARK RD
HASTINGS MI 49058

**This is to certify that
representative samples of**

SPRINKLERS, EARLY SUPPRESSION FAST RESPONSE
Viking SIN VK514 28K pendent style, ESFR sprinkler rated
165°F and 205°F maximum ceiling heights of 48 ft. and
maximum commodity height of 43 ft. with a maximum
deflector to ceiling distance of 14 in.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1767, Early-Suppression Fast-Response Sprinklers
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

