



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK302	5.6	Pendent	QR	3 mm	1/2	Brass, Chrome, Polyester, NICOTEF	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
VK302	5.6	Recessed Pendent	QR	3 mm	1/2	Brass, Chrome, Polyester, NICOTEF	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

or

The Viking Corporation, 11305 James Street, Holland, MI 49424, USA

FM Approvals Class: 2017, 2015

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR449184

Approval Granted: October 5, 2018

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA