



Certificate of Compliance

This certificate is issued for the following equipment:

Quick Response Storage Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK514	28.0	Pendent	QR (ESFR) Storage	Fusible	1	Brass	165, 205 (74, 96)

Prepared for:

The Viking Corporation, 5150 Beltway Drive SE,
Caledonia, MI 49316 USA

Manufacturing Location:

The Viking Corporation, 210 North Industrial Park Drive,
Hastings, MI 49058 USA

FM Approvals Class: 2035

FM Approval Standard: Class Series 2008 (February 2018)

Approval Identification: PR455623

Approval Granted: July 31, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller", written over a horizontal line.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group