



# Certificate of Compliance

This certificate is issued for the following equipment:

## Open Water-Spray Nozzles for Fire Protection

Model	Nominal K-Factor (gpm/(psi) <sup>1/2</sup> )	Nominal Spray Angle (Degrees)	Nominal Thread Size (in.)	Finishes
C-2 (VK771)	3.3	60	1/2	Brass, Electroless Nickel Plating

Prepared for: The Viking Corporation, 5150 Beltway Drive SE, Caledonia, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2025

FM Approval Standard: Class Series 2021/2025 (February 2010)

Approval Identification: PR456400

Approval Granted: May 11, 2020

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group