



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK481	5.6	Concealed Horizontal Sidewall	SR	Fusible	1/2	Brass	165, 205 (74, 96)

Prepared for:

The Viking Corporation
5150 Beltway Drive SE, Caledonia, MI 49316, USA

Manufacturing Location:

The Viking Corporation
210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2015

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR462599

Approval Granted: November 2, 2022

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

