



VJPZC.EX1193 Quick Opening Devices, Accelerators and Exhausters

[Page Bottom](#)

Quick Opening Devices, Accelerators and Exhausters

[See General Information for Quick Opening Devices, Accelerators and Exhausters](#)

VIKING CORP

EX1193

210 N INDUSTRIAL PARK RD
HASTINGS, MI 49058 USA

Model D-1 accelerator for use with "Viking" Model E-1 dry pipe valves of nominal pipe sizes 3, 4 and 6, and for system capacities up to 10 600 L.

Model E-1 accelerator and Model B-1 anti-flooding device for use with "Viking" Models E-1, E-2 and F-1 dry pipe valves of nominal pipe sizes 3, 4 and 6, as applicable. Maximum working pressure 1210 kPa.

[Last Updated](#) on 2004-02-27

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters' Laboratories of Canada®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certifications Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge.

