

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK100	5.6	Upright	SR	5mm	1/2	Brass, Chrome, NICOTEF Coated, Polyester, Wax	135, 155, 175, 200, 212, 286, 360, 500 (57, 68, 79, 93, 100, 141, 182, 260)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060665 Approval Granted: October 23, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA





This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK200	8.0	Upright	SR	5mm	1/2, 3/4	Brass, Chrome, Polyester, NICOTEF Coated	135, 155, 175, 200, 286, 360, 500 (57, 68, 79, 93, 141, 182, 260)
VK206	8.0	Pendent	SR	Fusible	3/4	Brass	165, 220, 286 (74, 104, 141)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2001

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060665 Approval Granted: October 23, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA





This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK300	5.6	Upright	QR	3mm	1/2	Brass, Chrome, Polyester, NICOTEF Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
VK301	5.6	Upright	QR	Fusible	1/2	Brass, Chrome, Polyester	165, 205, 280 (74, 96, 138)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060665 Approval Granted: October 23, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA





This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK350	8.0	Upright	QR	3mm	1/2, 3/4	Brass, Chrome, Polyester, NICOTEF Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
VK351	8.0	Upright	QR	Fusible	1/2	Brass, Chrome, Polyester	165, 205, 280 (74, 96, 138)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2001

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060665 Approval Granted: October 23, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager - Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA





This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK338	5.6	Upright	QR	3mm	1/2	Stainless Steel Alloy 316L (UNS-NO8367)	155, 175 (68, 79)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2042

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060665 Approval Granted: October 23, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA

