

CERTIFICATE OF COMPLIANCE

Certificate Number 20140627-EX3836
Report Reference EX3836-20131221
Issue Date 2014-JUNE-27

Issued to: VIKING CORP
210 N INDUSTRIAL PARK RD
HASTINGS MI 49058


**This is to certify that
representative samples of** RESIDENTIAL AUTOMATIC SPRINKLERS
See next page for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL1626 - Standard for Residential Sprinklers for Fire-
Protection Service
ULC/ORD C-1626-03 - Other Recognized Document for
Residential Sprinklers for Fire-Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus




CERTIFICATE OF COMPLIANCE

Certificate Number 20140627-EX3836
Report Reference EX3836-20131221
Issue Date 2014-JUNE-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

VK467 upright style sprinkler, discharge coefficient "K" = 4.9, (3 mm glass bulb type) heat responsive element, 155 and 175 °F temperature rated residential type sprinklers.

VK4670 (Lead Free) upright style sprinkler, discharge coefficient "K" = 4.9, (3 mm glass bulb type) heat responsive element, 155 and 175 °F temperature rated residential type sprinklers.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

