

CERTIFICATE OF COMPLIANCE

Certificate Number 20150326-EX3836
Report Reference EX3836-20050318
Issue Date 2015-MARCH-26

Issued to: VIKING CORP
210 INDUSTRIAL PARK DR HASTINGS MI 49058-9706

**This is to certify that
representative samples of**

RESIDENTIAL AUTOMATIC SPRINKLERS; RESIDENTIAL AUTOMATIC SPRINKLERS CERTIFIED FOR EUROPE VK460, VK479, VK486, VK4860, and VK4600 horizontal sidewall sprinklers, ½ in. recess discharge coefficient “K” = 3.0, 4.0 and 5.8, (3 mm glass bulb type) heat responsive element, 155 and 175 °F temperature rated residential type sprinklers. These sprinklers have a maximum pressure of 175 psig for wet systems only for spacings

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1626 STANDARD FOR RESIDENTIAL SPRINKLERS FOR FIRE-PROTECTION SERVICE

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

